# FINAL REMEDIAL ACTION CONSTRUCTION DRAWINGS

THE ELLIS PROPERTY SUPERFUND SITE

150 SHARP ROAD

EVESHAM TOWNSHIP


BURLINGTON COUNTY, NEW JERSEY

PREPARED FOR: PREPARED BY:



HDR OBG a joint venture

## MARCH 2019



LOCATION MAP

# CONSTRUCTION DRAWING INDEX

SHEET	TITLE
G-00	COVER SHEET
G-01	GENERAL NOTES
V-01	EXISTING CONDITIONS PLAN
C-01	REMEDIAL ACTION SITE PLAN
C-02	UTILITY RELOCATION PLAN
C-03	CONSTRUCTION STAGING PLAN
C-04	EROSION AND SEDIMENT CONTROL PLAN
C-05	EXCAVATION PLAN
C-06	EXCAVATION GRADING PLAN
C-07	EXCAVATION DETAIL
C-08	SITE RESTORATION GRADING PLAN
C-09	SITE RESTORATION REVEGETATION PLAN
D-01	EXISTING GROUNDWATER BARRIER WALL DETAILS
D-02	CONSTRUCTION DETAILS SHEET 1
D-03	CONSTRUCTION DETAILS SHEET 2
D-04	EROSION CONTROL DETAILS

#### **GENERAL NOTES:**

- 1. ALL WORK SHALL BE PERFORMED IN STRICT ACCORDANCE WITH ALL APPLICABLE FEDERAL, STATE, AND LOCAL CODES AND REGULATIONS.
- THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS BEFORE BEGINNING WORK.
- 3. SITE IS LOCATED AT 150 SHARP ROAD IN EVESHAM TOWNSHIP, BURLINGTON COUNTY, NEW JERSEY.
- 4. ACCESS TO THE SITE WAS OBTAINED THROUGH A CONSENT ORDER ISSUED IN 1996.
- 5. ALL SITE FEATURES SHALL BE FIELD VERIFIED BY CONTRACTOR PRIOR TO CONSTRUCTION. ANY DISCREPANCIES NOTED SHALL BE IMMEDIATELY BROUGHT TO THE ATTENTION OF THE CONTRACTING OFFICER.
- 6. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE A GEOPHYSICAL SURVEY COMPLETED TO LOCATE ALL EXISTING UNDERGROUND UTILITIES AND STRUCTURES WHETHER SHOWN ON THIS PLAN OR NOT, AND TO PROTECT THEM FROM DAMAGE. THE SURVEY SHALL INCLUDE THE LOCATION OF THE EXISTING GROUNDWATER BARRIER
- 7. IN THE EVENT THE CONTRACTOR DAMAGES ANY EXISTING UTILITY SERVICE CAUSING SERVICE INTERRUPTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE CONTRACTING OFFICER.
- 8. PROVISIONS SHALL BE TAKEN TO MINIMIZE NOISE. CONSTRUCTION ACTIVITIES ARE NOT PERMITTED BETWEEN THE HOURS OF 6PM TO 7AM.
- 9. THE CONTRACTOR IS RESPONSIBLE FOR ENSURING UNAUTHORIZED PERSONS DO NOT ENTER THE EXCLUSION ZONE. SNOW FENCE OR OTHER ACCEPTABLE MEANS SHALL BE PROVIDED AROUND THE HAZARDOUS WORK ZONE TO RESTRICT ACCESS.
- 10. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SECURITY OF THE SITE. ANY REPAIRS RESULTING FROM DAMAGE CAUSED BY TRESPASSERS SHALL BE AT THE EXPENSE OF THE CONTRACTOR. MINIMUM SECURITY MEASURES SHALL BE AS REQUIRED BY THE CONTRACT SPECIFICATIONS.
- 11. ALL AREAS DISTURBED BY THE CONTRACTOR SHALL BE RESTORED TO THEIR ORIGINAL CONDITIONS TO THE SATISFACTION OF THE CONTRACTING OFFICER.

#### SURVEY NOTES:

- 1. SURVEY BY MERESTONE CONSULTING INC. DATED NOVEMBER 12, 2014.
- 2. HORIZONTAL DATUM = NJSPCS NAD83(NA2011) EPOCH 2010.0000.
- 3. VERTICAL DATUM = NAVD 1988 (GEOID 2012A).
- 4. LOCATION OF THE SHEET PILE WALL IS BASED ON SHEET 3 OF 7 OF THE PLAN SET ENTITLED ELLIS PROPERTY SUPERFUND SITE, GROUND WATER BARRIER WALL, DATED APRIL 22, 2011, PREPARED BY THE LOUIS BERGER GROUP, INC.

## WASTE DISPOSAL NOTES:

- 1. THE CONTRACTOR MUST TAKE EVERY EFFORT TO REDUCE THE AMOUNT OF WASTE THAT IS GENERATED, TO REUSE MATERIALS WITH THE CONCURRENCE OF THE CONTRACTING OFFICER, AND TO SEGREGATE WASTE MATERIALS FOR WASTE DISPOSAL.
- 2. ALL WASTE MATERIALS MUST BE PROPERLY TRANSPORTED, STORED, HANDLED, AND CONTAINED TO PREVENT SPILLS, LEAKAGE, DISCHARGE OR RELEASE TO THE ENVIRONMENT. WASTE CONTAINERS MUST BE PROPERLY LABELED TO IDENTIFY CONTENTS.
- 3. CONTRACTOR MUST NOT DISCHARGE OR DISPOSE OF ANY WASTE INTO ANY WATER BODY.
- 4. CONTRACTOR MUST DISPOSE OF ALL WASTE MATERIALS ACCORDING TO ALL LOCAL, STATE AND FEDERAL REGULATIONS.
- 5. THE REGIONAL OFF-SITE COORDINATOR FOR EPA REGION 2 SHALL APPROVE THE WASTE DISPOSAL FACILITY SELECTED BY THE CONTRACTOR. ALL WASTE MANIFESTS REQUIRED FOR THE PROJECT SHALL BE PREPARED AND SIGNED BY THE CONTRACTING OFFICER.

#### **EXCAVATION NOTES:**

- 1. EXCAVATION EQUIPMENT AND WORK SHALL COMPLY WITH ALL FEDERAL, STATE, AND LOCAL CODES AND REGULATIONS INCLUDING BUT NOT LIMITED TO OSHA 29 CFR 1926, SUBPARTS M, O, AND P.
- 2. THE CONTRACTOR SHALL PERFORM THE EXCAVATIONS AT THE MINIMUM DEPTHS SHOWN ON THE PLANS. THE EXCAVATION LIMITS SHOWN MAY BE ENLARGED BASED ON THE RESULTS OF THE POST EXCAVATION SAMPLE RESULTS. ALL EXCAVATIONS BEYOND THE DEPTHS OR LIMITS SHOWN SHALL BE APPROVED BY THE CONTRACTING OFFICER PRIOR TO COMMENCING.
- 3. ESTIMATED VOLUME OF SOIL TO BE REMOVED IS NOT NECESSARILY EQUAL TO THE ACTUAL VOLUME THAT WILL BE REMOVED. THE CONTRACTOR SHALL SLOPE AND/OR SHORE EXCAVATIONS TO PROTECT EXISTING STRUCTURES AND UTILITIES THAT ARE TO REMAIN.
- 4. METHODS USED FOR PROTECTING INDIVIDUALS WITHIN AN EXCAVATION SHALL MEET THE REQUIREMENTS OF 29 CFR 1926.625. STRUCTURAL METHODS, IF NOT DESIGNED USING TABULATED DATA SHALL BE DESIGNED AND CERTIFIED BY A NJ LICENSED PROFESSIONAL ENGINEER.
- AND CERTIFIED BY A NJ LICENSED PROFESSIONAL ENGINEER.

  5. PROVIDE BARRICADES, COVERINGS, OR OTHER TYPES OF PROTECTION NECESSARY TO PREVENT DAMAGE TO EXISTING STRUCTURES AND UTILITIES
- 6. COORDINATES PROVIDED FOR STAKE OUT ARE BASED ON STATE PLANE DATUM AND ARE ESTIMATED TO THE NEAREST HUNDREDTH OF A FOOT +/-.
- 7. CONTRACTOR MUST PROVIDE LADDERS, STAIRWAYS, RAMPS, OR OTHER SAFE MEANS OF EGRESS IN ALL EXCAVATIONS THAT ARE FOUR FEET DEEP OR MORE SO THAT A WORKER DOES NOT NEED TO TRAVEL MORE THAN 25 FEET IN ANY DIRECTION BEFORE BEING ABLE TO EXIT THE EXCAVATION.
- 8. DIRT, DEBRIS, AND OTHER MATERIAL MUST BE EFFECTIVELY STORED AND RETAINED AT LEAST TWO FEET FROM THE EDGE OF EXCAVATIONS THAT PERSONNEL MAY BE REQUIRED TO ENTER.
- 9. THE CONTRACTOR SHALL LIMIT THE AREA OF OPEN EXCAVATION TO NO MORE THAN 20,000 SF AT ANY ONE TIME.

## LAND GRADING NOTES:

TO REMAIN IN PLACE.

- 1. PROVISIONS SHALL BE MADE TO DIVERT SURFACE RUNOFF AWAY FROM EXPOSED AREAS AND OPEN EXCAVATIONS. RUNOFF THAT COMES IN CONTACT WITH IMPACTED SOILS SHALL BE COLLECTED AND EITHER TREATED IN A TEMPORARY GROUNDWATER TREATMENT SYSTEM PROVIDED BY THE CONTRACTOR OR DISPOSED OFF—SITE TO AN APPROVED FACILITY.
- 2. ALL GRADED OR DISTURBED AREAS, INCLUDING SLOPES, SHALL BE PROPERLY PROTECTED DURING CLEARING AND CONSTRUCTION IN ACCORDANCE WITH THE EROSION AND SEDIMENT CONTROL PLAN UNTIL THEY ARE ADEQUATELY STABILIZED.
- 3. ALL EROSION AND SEDIMENT CONTROL PRACTICES AND MEASURES SHALL BE CONSTRUCTED, APPLIED, AND MAINTAINED IN ACCORDANCE WITH THE SEDIMENT CONTROL PLAN AND THE "NEW JERSEY EROSION CONTROL STANDARDS.
- 4. AREAS THAT ARE TO BE TOPSOILED SHALL BE SCARIFIED TO A MINIMUM DEPTH OF FOUR INCHES PRIOR TO PLACEMENT OF TOPSOIL.
- 5. ALL FILL SHALL BE COMPACTED AS REQUIRED TO REDUCE EROSION, SLIPPAGE, SETTLEMENT, SUBSIDENCE, OR OTHER RELATED PROBLEMS. FILL INTENDED TO SUPPORT BUILDINGS, STRUCTURES, AND CONDUITS, ETC., SHALL BE COMPACTED IN ACCORDANCE WITH LOCAL REQUIREMENTS OR CODES.
- 6. ALL FILL SHALL BE PLACED AND COMPACTED IN LAYERS NOT TO EXCEED 12 INCHES IN THICKNESS.
- 7. FILL MATERIAL SHALL BE FREE OF FROZEN PARTICLES, BRUSH, ROOTS, SOD, OR OTHER FOREIGN OBJECTIONABLE MATERIALS THAT WOULD INTERFERE WITH, OR PREVENT, CONSTRUCTION OF SATISFACTORY FILLS. FILL MATERIAL MUST MEET THE DEFINITION OF CLEAN FILL PROMULGATED AT NJAC 7:26E-1.8 AND NJDEP'S FILL MATERIAL GUIDANCE FOR SRP SITES.
- 8. FILL SHALL NOT BE PLACED ON SATURATED OR FROZEN SURFACES.
- 9. SEEPS OR SPRINGS ENCOUNTERED DURING CONSTRUCTION SHALL BE HANDLED IN ACCORDANCE WITH THE CONTRACT SPECIFICATIONS.
- 10. ALL GRADED AREAS SHALL BE PERMANENTLY STABILIZED IMMEDIATELY FOLLOWING FINISHED GRADING.
- 11. STOCKPILES, BORROW AREAS, AND SPOIL AREAS SHALL BE PROTECTED AS REQUIRED BY THE CONTACT DOCUMENTS. STOCKPILES SHALL NOT BE STORED WITHIN 50 FEET OF A WATER BODY OR IN ANY DRAINAGE PATHS. ALL MATERIALS SHALL BE ENCIRCLED WITH SILT FENCE AND COVERED WHEN NOT IN USE.

## CONSTRUCTION SEQUENCE:

- A PRELIMINARY SCHEDULE FOR THE ACTIVITIES NECESSARY TO COMPLETE THE REMEDIAL ACTION (RA) IS BELOW. THE ACTUAL SEQUENCE WILL BE DETERMINED BY THE CONTRACTOR AND SHALL BE INCLUDED IN THE WORK PLAN THAT WILL BE SUBMITTED PRIOR TO COMMENCING THE WORK.
- 1. UNDERGROUND UTILITY LOCATION: ALL UNDERGROUND UTILITIES AND THE EXISTING GROUNDWATER BARRIER WALL SHALL BE LOCATED.
- 2. MOBILIZATION: TRAILERS AND EQUIPMENT SHALL BE MOBILIZED TO THE SITE. ADDITIONALLY THE CONTRACTOR SHALL BEGIN SECURING THE POWER DROP FOR THE ISTT. THE ISTT IS NOT INCLUDED IN THIS CONTRACT AND WILL BE PERFORMED UNDER A SEPARATE FUTURE CONTRACT.
- 3. SITE PREPARATION: INSTALL THE TEMPORARY CHAIN LINK FENCE, ALL EROSION CONTROL MEASURES, CONSTRUCT THE STABILIZED CONSTRUCTION ENTRANCE.
- 4. TREE CLEARING: CLEAR TREES FROM THE EXCAVATION AREA. CHIP TREES AND SPREAD IN AREAS OUTSIDE THE CONSTRUCTION LIMITS OR STOCKPILE FOR USE AS MULCH DURING FINAL RESTORATION.
- 5. DEMOLITION/WELL ABANDONMENT: ABANDON EXISTING PIPING IN THE RA AREA AND RELOCATE PIPES AROUND RA AREA, AS SHOWN ON PLANS.
- 6. EXCAVATE AREA A: THE VEGETATION AND TOPSOIL SHALL BE REMOVED FROM EXCAVATION AREA A. TOPSOIL SHALL BE STOCKPILED FOR REUSE. THE TOP TEN FEET OF CLEAN SOIL SHALL ALSO BE REMOVED AND STOCKPILED FOR REUSE. AFTER REMOVING THE CLEAN SOIL, THE IMPACTED SOIL SHALL BE EXCAVATED TO A TARGET DEPTH OF 20 FEET BGS. SAMPLES SHALL BE COLLECTED TO VERIFY THE LIMITS. NOTE THAT THE SIDE OF THE EXCAVATION ADJACENT TO THE ISTT AREA MAY STILL BE CONTAMINATED AND IS INTENDED TO BE TREATED BY ISTT UNDER A SEPARATE CONTRACT. ONCE THE SAMPLE RESULTS ARE RECEIVED AND APPROVED BY THE CONTRACTING OFFICER, THE AREA SHALL BE BACKFILLED. ONCE BACKFILLED THE AREA SHALL BE COVERED WITH STOCKPILED TOPSOIL TO A DEPTH OF 4 INCHES, SEEDED AND COVERED WITH MULCH.
- 7. EXCAVATE AREA B: THE VEGETATION AND TOPSOIL SHALL BE STRIPPED IN 5,000 SQUARE FEET AREAS OF EXCAVATION AREA B. ONCE EACH AREA IS STRIPPED, THE TOP TEN FEET OF SOIL WILL BE REMOVED AND STOCKPILED FOR REUSE. THE IMPACTED SOILS WILL THEN BE REMOVED TO THE TARGET DEPTHS (BETWEEN 15–18 FEET BGS). CONFIRMATORY SAMPLES WILL BE COLLECTED. NOTE THAT THE SIDE OF THE EXCAVATION ADJACENT TO THE ISTT AREA MAY STILL BE CONTAMINATED AND IS INTENDED TO BE TREATED BY ISTT UNDER A SEPARATE CONTRACT. ONCE PASSING RESULTS ARE RECEIVED AND APPROVED BY THE CONTRACTING OFFICER, THE AREA SHALL BE BACKFILLED. ONCE BACKFILLED, THE AREA SHALL BE TOPPED WITH TOPSOIL, SEEDED AND MULCHED.

### MAINTENANCE AND PROTECTION OF TRAFFIC:

- 1. ALL TRAFFIC CONTROL DEVICES USED FOR MAINTENANCE AND PROTECTION OF TRAFFIC SHALL CONFORM TO THE APPLICABLE SPECIFICATIONS AS SET FORTH IN THE NATIONAL MUTCD 2003 EDITION.
- 2. THE CONTRACTOR SHALL NOT PARK EQUIPMENT OR STORE MATERIAL OVERNIGHT WHERE IT IS DEEMED BY THE CONTRACTING OFFICER TO BE A HAZARD TO TRAFFIC.
- 3. THE CONTRACTOR SHALL NOT ALLOW CONSTRUCTION RELATED VEHICLES OR ACTIVITIES TO IMPEDE OR ADVERSELY AFFECT THE FLOW OF TRAFFIC ON THE SHARP ROAD. THE CONTRACTOR SHALL NOT ALLOW CONSTRUCTION RELATED VEHICLES TO QUEUE ALONG SHARP ROAD WITHOUT PRIOR APPROVAL FROM THE CONTRACTING OFFICER.
- 4. DURING THE PROGRESS OF CONSTRUCTION, TRUCKS ENTERING OR LEAVING THE SITE SHALL USE ONLY ROADS THAT PERMIT TRUCK TRAVEL AS GOVERNED BY ANY AGENCY HAVING JURISDICTION. ALL ROADWAYS AFFECTED BY CONSTRUCTION OF THIS PROJECT SHALL BE RESTORED TO PRECONSTRUCTION CONDITIONS.
- 5. FLAGMEN PROVIDED BY THE CONTRACTOR SHALL BE ON SITE WHENEVER TRUCKS ENTER OR EXIT THE SITE TO ALLOW THE SAFE ENTERING AND EXITING OF SINGLE VEHICLES ONTO SHARP ROAD AND TO MINIMIZE QUEUING ON SHARP ROAD.

### ENVIRONMENTAL NOTES:

- THE CONTRACTOR SHALL REDUCE VEHICLE IDLING. ALL VEHICLES, BOTH
  ON AND OFF ROAD (INCLUDING CONSTRUCTION EQUIPMENT) SHALL BE
  SHUT OFF WHEN NOT IN USE FOR MORE THAN 5 MINUTES.
- 2. CONTRACTORS MUST NOT SPILL, DISCHARGE, OR RELEASE ANY HAZARDOUS MATERIAL OR CHEMICAL UPON OR FROM THE SITE. A RELEASE IS DEFINED AS ANY UNPLANNED RELEASE, LEAKING, PUMPING, POURING, EMITTING, DUMPING, DISCHARGING, EMPTYING, OR DISPOSING OF A HAZARDOUS MATERIAL OR CHEMICAL (INCLUDING WASTEWATER OR CHEMICALLY TREATED WATER) FROM A PRIMARY CONTAINMENT.
- 3. CONTRACTOR EQUIPMENT MUST BE PROPERLY MAINTAINED AND IS SUBJECT TO INSPECTION BY THE CONTRACTING OFFICER. IF EQUIPMENT IS FOUND LEAKING, IT MUST IMMEDIATELY BE CONTAINED, STOPPED, AND REPAIRED. ALL ASSOCIATED COSTS INCLUDING CLEANUP WILL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR.
- 4. UNREPORTED SPILLS, DISCHARGES, AND RELEASES ARE A VIOLATION OF FEDERAL, STATE, AND LOCAL LAWS. IF A CHEMICAL OR UNKNOWN LIQUID IS SPILLED, DISCHARGED, OR RELEASED TO THE PROPERTY, THE CONTRACTOR MUST IMMEDIATELY NOTIFY THE CONTRACTING OFFICER.
- 5. WHEN A SPILL, DISCHARGE, OR RELEASE IS DIRECTLY ATTRIBUTABLE TO A CONTRACTOR, THEIR SUBCONTRACTOR OR SUPPLIER, THE CONTRACTOR MUST PROVIDE ANY ASSISTANCE REQUIRED TO IDENTIFY THE CAUSE OF THE RELEASE AND TO CLEAN UP THE RELEASE. HOWEVER CONTRACTORS MUST NOT BEGIN CLEAN UP UNTIL AUTHORIZED TO DO SO BY THE CONTRACTING OFFICER.
- 6. ANY CHEMICAL SPILL, DISCHARGE, OR RELEASE CAUSED BY THE CONTRACTOR MUST BE CLEANED TO THE THE CONTRACTING OFFICER'S SATISFACTION. ALL ASSOCIATED CLEANUP COSTS ARE THE RESPONSIBILITY OF THE RESPONSIBLE CONTRACTOR.



US Army Corps of Engineers ® Kansas City District

ORIGINAL SIGNED AND SEALED BY

		6	2	2	2	2	Appr.
		02/11/1	1/01/60	08/27/15	1/91//0	05/27/15	Date
		REVISED FINAL RA CONSTRUCTION DRAWINGS 02/11/19	REVISED FINAL RA CONSTRUCTION DRAWINGS 09/10/15	FINAL RA CONSTRUCTION DRAWINGS	DRAFT FINAL RA CONSTRUCTION DRAWINGS 07/16/15	INTERMEDIATE DESIGN	Description
		5	4	3	2	1	Symbol
$\bar{}$	2		T				

Submitted by: CADD File Name:		a joint venture	7 OBG
Plot scale:	Checked by:		700
Drawing code:	Drawn by: SK	MISSOURI	KANSAS CITY, MISSOURI
08/27/2015	TC	OF ENGINEERS DISTRICT	U.S. AKMY COKPS OF ENGINEERS KANSAS CITY DISTRICT

I

EVESHAM LOWNSHIP, NEW JERSEY
GENERAL NOTES

Sheet Reference Number:

G-01



US Army Corps of Engineers® Kansas City District

	REVISED FINAL RA CONSTRUCTION DRAWINGS 02/11/19	02/11/19	
	REVISED FINAL RA CONSTRUCTION DRAWINGS 09/10/15	21/01/60	
	FINAL RA CONSTRUCTION DRAWINGS	08/27/15	
	DRAFT FINAL RA CONSTRUCTION DRAWINGS 07/16/15	51/91/20	
	INTERMEDIATE DESIGN	05/27/15	
(Symbol	Description	Date	Appr.

a joi

OBG

2

무

5

CONDITIONS

**EXISTIN**(

----- APPROXIMATE PROPERTY BOUNDARY WETLAND LIMIT
CONTOUR MAJOR
CONTOUR MINOR
BUILDING OUTLINE MONITORING WELL LOCATION

GRAVEL ROAD


WL-SB2 WETLAND SOIL BORING \_\_ \_ \_ 100-FT WETLAND BUFFER UNDERGROUND CONTROL CABLE (APPROX. LOCATION)


UNDERGROUND ELECTRIC LINE (APPROX. LOCATION) ELECTRIC POLE CHAIN LINK FENCE


- 1. FOR GENERAL NOTES REFER TO SHEET G-01.
- 2. THE EXISTING CHAIN LINK FENCE AROUND THE SITE BUILDING MUST BE REMOVED AS A PART OF EXCAVATION.
- 1. SURVEY BY MERESTONE CONSULTING INC. DATED NOVEMBER 12,
- 2. HORIZONTAL DATUM = NJSPCS NAD83(NA2011) EPOCH
- 4. LOCATION OF THE SHEET PILE WALL IS BASED ON SHEET 3 OF 7 OF THE PLAN SET ENTITLED ELLIS PROPERTY SUPERFUND SITE, GROUND WATER BARRIER WALL, DATED APRIL 22, 2011, PREPARED BY THE LOUIS BERGER GROUP, INC.
- 5. APPROXIMATE PROPERTY BOUNDARY WAS OBTAINED FROM 100% DESIGN DRAWINGS PREPARED BY ACRES INTERNATIONAL CORPORATION DATED 09/10/1998.

GRAPHIC SCALE ( IN FEET ) 1 inch = 60 ft.

Sheet Reference Number: V-01







US Army Corps Kansas City District


		REVISED FINAL RA CONSTRUCTION DRAW	REVISED FINAL RA CONSTRUCTION DRAV	נפס ייסודטיומדטיוסט גם יגואים מזט"יםם	REVISED FINAL RA CONSTRUCTION DRAW	FINAL RA CONSTRUCTION DRAWINGS	DRAFT FINAL RA CONSTRUCTION DRAWIN	INTERMEDIATE DESIGN	INTERNICULA CONTRA	اا Description	
		9	5	,	4	3	6	1 -		Symbol	
	08/27/2015	Drawing code:	, , , , , , , , , , , , , , , , , , ,			Flot scale:		Submitted by: CADD File Name:			
,	ე	Drawn by:	SK SY		Ob 1:- 4	checked by:   Plot scale:		Submitted by:	ç	10	
/ k	RICT	SOURI					oint venture				


a jo OBG HD


CONSTRUCTION STAGING PLAN


Sheet Reference Number:

C - 03











## EXCAVATION ALONG EXISTING SHEET PILE WALL DETAIL

 $\frac{\text{SCALE}}{\text{VERTICAL: } 1" = 5'}$ HORIZONTAL: 1" = 10"





## EXCAVATION DETAIL SCALE:

 $\overline{\text{VERTICAL: }}$ 1" = 5' HORIZONTAL: 1" = 10'

1. EXISTING STEEL SHEET PILES ARE DRIVEN TO MINIMUM 30 FT BELOW EXISTING GROUND SURFACE OR TO ELEVATION 40 FT AMSL, WHICHEVER IS DEEPER. SHEET PILES ARE SOCKETED AT LEAST 5 FT INTO NAVESINK FORMATION.

2. FUTURE EXCAVATION OF IMPACTED SOIL AREA MUST BE SLOPED AT A GRADIENT OF 1.5H:1.0V, OR FLATTER.

3. IF CLEAN SIDEWALLS ARE NOT OBTAINED THE CONTRACTOR WILL INCREMENTALLY EXCAVATE CLOSER TO THE SHEET PILE WALL WHILE MAINTAINING THE MAXIMUM SLOPE OF 1.5H:1V. THE CONTRACTOR SHALL EXCAVATE BEHIND THE SHEET PILE WALL AS NEEDED TO MAINTAIN THE MAXIMUM SLOPE. CONTRACTOR MAY PROPOSE AN ALTERNATIVE MEANS TO EXCAVATE DEEPER FOR APPROVAL BY THE CONTRACTING OFFICER.

## EXCAVATION ALONG EXISTING SHEET PILES SCALE: N.T.S.

US Army Corps of Engineers ® Kansas City District


02/11/19 09/10/15 08/27/15 07/16/15 05/27/15

OBG H


 $\overline{\triangleleft}$ XCAVATION


> Sheet Reference Number:


C - 07



9	REVISED	FINAL	₹	REVISED FINAL RA CONSTRUCTION DRAWINGS 03/25/19	N DRAWI	NGS	03/25/19	
2	REVISED	FINAL	Æ	REVISED FINAL RA CONSTRUCTION DRAWINGS 02/11/19	N DRAW	NGS	02/11/19	
4	REVISED	FINAL	Æ	REVISED FINAL RA CONSTRUCTION DRAWINGS 09/10/15	N DRAWI	NGS	09/10/15	
3	FINAL RA	CONS	STRU	FINAL RA CONSTRUCTION DRAWINGS	GS S		08/27/15	
2	DRAFT F	INAL R	AC	DRAFT FINAL RA CONSTRUCTION DRAWINGS	DRAWING		07/16/15	
-	INTERMEDIATE DESIGN	DIATE [	)ESI	NO			05/27/15	
Symbol			۵	Description			Date	App








## SEALANT FILLING THE FREE INTERLOCKS

STEEL SHEET PILE WALL SECTION SCALE: N.T.S. 8 - 12 MM \* \* THIS DIMENSION IS ONLY FOR APPLICATION OF HOT BITUMINOUS SEALANT

HOT BITUMINOUS SEALANT: LEADING HOT BITUMINOUS SEALANT: INTERLOCK WITHOUT SEALANT INTERLOCK WITH SEALANT

COLD WATER-SWELLING SEALANT: INTERLOCK WITH SEALANT COLD WATER-SWELLING SEALANT: AND SEALANT TO BE LUBRICATED WITH A COMMERCIAL INTERLOCK WITHOUT SEALANT. SOAP-BASED PRODUCT IN ACCORDANCE WITH SPECIFICATION LEADING INTERLOCK SHALL BE SECTION 31 41 16 - GROUNDWATER BARRIER WALL. CLEANED IN ACCORDANCE WITH SPECIFICATION SECTION 31 41 16 GROUNDWATER BARRIER WALL.




HOT BITUMINOUS OR WATER-SWELLING SEALANT


SEALANT FILLING THE THREADED INTERLOCKS

# SCALE: N.T.S.

# THREADED SHEET PILES INSTALLATION ALONG TYPICAL CROSS-SECTION



## SEALANT FEEDING INTO THE INTERLOCKS OF SINGLE SHEET PILES



SEALANT FEEDING INTO THE INTERLOCKS OF THREADED SHEET PILES SCALE: N.T.S.

HOT BITUMINOUS SEALANT: INTERLOCK WITHOUT SEALANT COLD WATER-SWELLING PRODUCT: INTERLOCK WITH SEALANT AND SEALANT TO BE LUBRICATED WITH A COMMERCIAL SOAP-BASED PRODUCT IN ACCORDANCE WITH SPECIFICATION SECTION 31 41 16 - GROUNDWATER BARRIER WALL. HOT BITUMINOUS SEALANT: LEADING INTERLOCK WITH SEALANT DRIVING DIRECTION COLD WATER-SWELLING PRODUCT: INTERLOCK WITHOUT SEALANT. TOP OF SHEET PILE SHALL BE LEADING INTERLOCK SHALL BE DRIVEN TO A MINIMUM OF 6-INCH CLEANED IN ACCORDANCE WITH SHEET PILE BELOW EXISTING SURFACE, SPECIFICATION SECTION 31 41 16 -GROUNDWATER BARRIER WALL. HORNERSTOWN (CLAY) HORNERSTOWN (SAND)

## SINGLE SHEET PILES INSTALLATION ALONG TYPICAL CROSS-SECTION SCALE: N.T.S.

THIS DRAWING SHOWS THE AS BUILT DETAILS FOR THE EXISTING SHEET PILE WALL. AS BUILT DETAILS WERE TAKEN FROM PLAN SET ENTITLED ELLIS PROPERTY SUPERFUND SITE GROUNDWATER BARRIER WALL PREPARED FOR NJDEP BY THE LOUIS BERGER GROUP, INC. DATED APRIL 22, 2011.

US Army Corps of Engineers® Kansas City District


u u	REVISED FINAL RA CONSTRUCTION DRAWINGS 92/11/19	02/11/19	
) 4	REVISED FINAL RA CONSTRUCTION DRAWINGS 92/10/18	21/01/60	
3	FINAL RA CONSTRUCTION DRAWINGS	08/27/15	
2	DRAFT FINAL RA CONSTRUCTION DRAWINGS 07/16/15	51/16/15	
	NTERMEDIATE DESIGN	05/27/15	
Symbol	Description	Date	Appr.


a joint ARMY CORPS ( KANSAS CITY KANSAS CITY U  $\mathbf{\Omega}$ 0 0


> I GROUNDWATER WALL DETAILS EXISTING BARRIER

Sheet Reference Number:

D - 01







NOTE:

1. FENCE SHALL BE INSTALLED TO WITHSTAND A SIDE PRESSURE OF 250 PSI.

2. IF POST CANNOT BE DRIVEN CONCRETE BASES MAY BE NEEDED.

CHAIN LINK SECURITY FENCE DETAIL 4
SCALE: N.T.S.

DOUBLE SWING GATE (TYPE FE7 FENCE) 5
SCALE: N.T.S.

US Army Corps of Engineers ® Kansas City District

SIGNATURE


					_
CODDS OF ENCINEEDS	Designed by:	Date:			
KANSAS CITY DISTRICT	TC	08/27/2015			
S CITY, MISSOURI	Drawn hv.	Drawing code.			
		500	5	REVISED FINAL RA CONSTRUCTION DRAWINGS 02/11/19	19
		- č	4	REVISED FINAL RA CONSTRUCTION DRAWINGS 09/10/15	15
	Unecked by:	Plot scale:	3	FINAL RA CONSTRUCTION DRAWINGS 08/27/15	15
A a joint venture			2	DRAFT FINAL RA CONSTRUCTION DRAWINGS 07/16/15	15
	Submitted by:	Submitted by: CADD File Name:	-	INTERMEDIATE DESIGN 05/27/15	15
	<u>5</u>		Symbol	Description Date	Appr.


ELLIS PROPERTY SUPERFUND SITE EVESHAM TOWNSHIP, NEW JERSEY
CONSTRUCTION DETAILS
SHEET 1


I


Sheet Reference Number:

D-02









1. PROVIDE TRACER WIRE FOR FULL LENGTH OF NONMETALLIC PIPE PER SPECIFICATION SECTION 33 11 00 - WATER DISTRIBUTION.

PROPOSED ELECTRICAL AND PUMP DISCHARGE LINES

SCALE: N.T.S.


4
D-03



PROJECT SIGNS 1 SCALE: N.T.S. 0-03


"NO TRESPASSING" SIGN SCALE: N.T.S. (P-03)

EXISTING COLLECTION TRENCH DETAIL (3)



. REPLACE ALL WATER, ELECTRICAL AND COMMUNICATION PIPING WITH HEAT RESISTANT MATERIALS AS SHOWN. THESE MATERIALS SHALL BE CAPABLE OF WITHSTANDING TEMPERATURES ANTICIPATED DURING THE ISTT WHICH COULD BE IN EXCESS OF 200 DEGREES CELSIUS.


EXISTING PUMPING WELL (PW-1 & PW-2) AS-BUILT DETAIL 6



## **NOTES**

- 1. MIN. PIT DIMENSIONS SHALL BE 4'X4'. 2. THE STANDPIPE SHOULD BE CONSTRUCTED BY PERFORATING A 24" DIAMETER
- CORRUGATED OR PVC PIPE. 3. A BASE OF STONE SHOULD BE PLACED IN THE PIT TO A DEPTH OF 12". AFTER INSTALLING THE STANDPIPE, THE PIT SURROUNDING THE STANDPIPE
- SHOULD BE BACKFILLED WITH 1-2" STONE. 4. THE STANDPIPE SHOULD EXTEND 12-18" ABOVE THE LIP OF THE PIT.

SUMP PIT 7
SCALE: N.T.S. D-03



## **NOTES**

1. PROVIDE CROWN ALONG ROAD TO PROMOTE DRAINAGE.

2. PROVIDE A MAXIMUM SLOPE OF 10%. 3. CLEAR AND STRIP ROADBED AND PARKING AREAS OF ALL VEGETATION, ROOTS AND OTHER OBJECTIONABLE MATERIAL.

RESTORED ACCESS ROAD SECTION DETAIL 5
SCALE: NOT TO SCALE

 $\overline{\triangleleft}$ ELLIS PROPERTY SUPERFUND SITE EVESHAM TOWNSHIP, NEW JERSEY XTIOI EET TRUC SHE

> Sheet Reference Number:

S Z 0  $\bigcirc$ 

O

U

 $\mathbf{\omega}$ 

0

0

I


C


S


US Army Corps of Engineers®

Kansas City District

D - 03











-STAPLE 6" SPACING

VERTICALLY

ABOUT 10 INCHES

AND BURY FLAP


STAPLE 6" SPACING-


VERTICALLY

DIRECTION OF RUNOFF

SECTION A







PROFILE AND PLAN VIEW

TEMPORARY STOCK PILE WITH SILT FENCE DETAIL (4) SCALE: N.T.S.

2. SILT FENCE SHALL BE PLACED SO AS TO CAPTURE ANY RUNOFF FROM THE STOCKPILE.

3. ALTERNATIVELY THE CONTRACTOR MAY COVER THE STOCKPILES WITH A GEO-MEMBRANE LINER.

STABILIZED CONSTRUCTION DRIVEWAY (5) SCALE: N.T.S.

#### SOIL EROSION AND SEDIMENT CONTROL NOTES:

- 1. All applicable erosion and sediment control practices shall be in place prior to
- any grading operation and/or installation of proposed structures or utilities. 2. Soil Erosion and sediment control practices on the plan shall be constructed in
- accordance with the Standards for Soil Erosion and Sediment Control in New 3. All applicable erosion and sediment control practices shall be left in place until
- construction is completed and/or the area is stabilized. 4. Any disturbed area that will be left exposed for more than sixty (60) days and not subject to construction traffic shall immediately receive a temporary seeding and fertilization in accordance with the Standards. If the season prohibits temporary seeding, the disturbed areas will be mulched with salt hay
- or equivalent and anchored in accordance with the Standards. 5. All critical areas subject to erosion will receive a temporary seeding in combination with straw mulch in accordance with the Standards immediately
- ollowing rough grading. 6. The site shall at all times be graded and maintained such that all stormwater runoff is diverted to soil erosion and sediment control facilities.
- 7. All soil erosion and sediment control structures will be inspected and
- maintained on a regular basis and after every storm event. 8. Soil Stockpiles are not to be located within fifty (50) feet of a floodplain, slope, roadway or drainage facility. The base of all stockpiles should be protected by a hay bale barrier or sediment fence. Proposed locations must be
- delineated on the plans. 9. A crushed stone tire cleaning pad will be installed wherever a construction access exists. The rip rap pad must be 100 feet in length and the stone must be 1.5" - 4" in size, placed 12" thick and the full width of the entrance. It should be underlain with a suitable synthetic filter fabric and maintained. The
- structure must be delineated and detailed on the plans. 10. If a stone construction access is to be used as an exit onto a major highway,
- a thirty (30) foot paved transition area shall be installed. 11. All driveways must be stabilized with 2 ½" crushed stone or sub base prior to individual lot construction.
- 12. Paved roadways must be kept clean at all times. 13. All catch basin inlets will be protected during construction (filter details appear
- on plan).
- 14. All storm drainage outlets will be stabilized before the discharge points become operational. 15. All dewatering operations must discharge directly into a sediment filtration device. The sediment filter must be placed so as not to cause erosion of the
- downstream area. Field placement and use of the structure must be approved by the District Erosion Control Inspector prior to commencement of dewatering
- 16. The Burlington County Soil Conservation District shall be notified 72 hours prior to any land disturbance.
- 17. Soil having a pH of 4.0 or less or containing iron sulfide must be covered with a minimum of 12 inches of soil having a pH of 5.0 or more before seedbed preparation.
- 18. It shall be the responsibility of the developer to provide confirmation of lime, fertilizer and seed application rates at the request of the Burlington County Soil Conservation District.
- 19. NJSA 4:24-39, et seq. requires that no Certificate of Occupancy be issued before all the provisions of the certified soil erosion and sediment control plan have been complied with for permanent measures. All site work for the project must be completed prior to the District issuing a report of compliance as a
- prerequisite to the issuance of a Certificate of Occupancy by the municipality. 20. NJSA 4:24-39, et seq. requires that upon permanent site stabilization and completion of construction the contractor shall apply to the Soil Conservation District for a final compliance inspection to check that all the provisions of the certified soil erosion and sediment control plan have been complied with for
- permanent measures. 21. Off-site sediment disturbance may require additional control measures to be
- determined by the District Erosion Control Inspector. 22. A copy of the certified soil erosion and sediment control plan must be
- maintained on the project site during construction. 23. Any conveyance of this project prior to its completion will transfer full
- responsibility for compliance with the certified plan to all subsequent owners. 24. Immediately after the completion of stripping and stockpiling topsoil, the stockpile shall be seeded with temporary vegetation. Stabilize topsoil stockpiles with straw mulch for protection if the season does not permit the
- establishment of temporary seed. 25. Any changes to the site plan will require the submission of a revised soil erosion and sediment control plan to the Burlington County Soil Conservation District. The revised plan must be in accordance with the current Standards for
- Soil Erosion and Sediment Control in New Jersey. 26. Maximum side slopes of all exposed surfaces shall not be constructed steeper
- 27. The District Erosion Control Inspector may require additional measures to be
- 28. Immediately prior to topsoil application, the subsoil shall be evaluated for
- compaction in accordance with the Standard for Land Grading. See details. 29. NJSA 4:24-39 et seq. requires that no Certificate of Occupancy be issued before the completion of a Soil Compaction Mitigation Verification Form and
- requirements in the Standard for Land Grading have been sufficiently addressed. 30. The responsibility for erosion controls for individual lots will transfer to subsequent owners of the lot. This responsibility will be described in the deed, and a single family home plan containing all necessary erosion controls will be
- provided to the owner. 31. Concrete truck washout areas will be maintained on a continual basis and as
- 32. The Stormwater Pollution Prevention Plan and the Spill Response Plan shall be available on site for review by the SCD Inspector and/or the NJDEP Inspector. 33. The SCD Inspector or NJDEP Inspector may require additional measures for
- Stormwater Pollution Prevention to be installed. 34. Inspections of all Stormwater Pollution Prevention Plan measures will be
- conducted and documented on a regular basis and after every storm event. 35. Waste collection containers will not be permitted to overflow. 36. Any spills of hazardous or sanitary wastes will be cleaned up immediately, and
- in accordance with the spill response plan. Spill kits must be available onsite or adjacent to the site. 37. Any Hazardous Substance releases in excess of reportable quantities (RQ)
- established under 40 C.F.R. 110, 117 and 302 that occur within a 24-hour period must be reported the National Response Center (800 424-8802).

## SOIL EROSION AND SEDIMENT CONTROL PERMIT REQUIREMENTS:

1. THE CONTRACTOR WILL RETAIN AN INDEPENDENT CONTRACTOR FOR COMPLETING THE SOIL EROSION AND SEDIMENT CONTROL PLAN APPROVAL PROCESS PRIOR TO PROJECT START, WHICH CONSISTS OF SUBMITTAL OF SOIL EROSION AND SEDIMENT CONTROL PLAN APPLICATIONS ALONG WITH REQUIRED SIGNED AND SEALED PLANS AND DETAILS TO THE BURLINGTON COUNTY SOIL CONSERVATION DISTRICT CERTIFICATIONS.

**US Army Corps** 

of Engineers ®

Kansas City District

0 4 W 0 4

D

 $\mathbf{\omega}$ 

0

00

 $\propto$ 

 $\bigcirc$ 

 $\overline{S}$ 

0

Sheet Reference Number: D - 04